

Detailed Asset List

COFFEE ON CUE
19 Hall St
YARRAVILLE 3013



Client: COFFEE ON CUE

Site: COFFEE ON CUE

Location: 22_02_23

Asset ID	Description	Make	Model	Serial No	Last Test	Next Test	Last Visual	Next Visual
JC00092595	COFFEE MCHINE				22/02/2023	22/02/2024	22/02/2023	
JC00092596	COFFEE MACHINE8				22/02/2023	22/02/2024	22/02/2023	
JC00092597	EXTN LEAD				22/02/2023	22/02/2024	22/02/2023	
JC00092598	RCD POWERBOARD				22/02/2023	22/02/2024	22/02/2023	
JC00092599	EXTN LEAD				22/02/2023	22/02/2024	22/02/2023	
JC00092600	EXTN LEAD				22/02/2023	22/02/2024	22/02/2023	
JC00092601	COFFEE MACHINE				22/02/2023	22/02/2024	22/02/2023	
JC00092602	COFFEE MACHINE				22/02/2023	22/02/2024	22/02/2023	
JC00092603	COFFEE GRINDER				22/02/2023	22/02/2024	22/02/2023	
JC00092604	COFFEE MACHINE				22/02/2023	22/02/2024	22/02/2023	
JC00092605	COFFEE MACHINE				22/02/2023	22/02/2024	22/02/2023	
JC00092606	COFFEE GRINDER				22/02/2023	22/02/2024	22/02/2023	
JC00092607	EXTN LEAD				22/02/2023	22/02/2024	22/02/2023	
JC00092608	EXTN LEAD				22/02/2023	22/02/2024	22/02/2023	
JC00092609	RCD POWERBOARD				22/02/2023	22/02/2024	22/02/2023	
JC00092610	EXTN LEAD				22/02/2023	22/02/2024	22/02/2023	
JC00092611	EXTN LEAD				22/02/2023	22/02/2024	22/02/2023	
JC00092612	COFFEE MACHINE				22/02/2023	22/02/2024	22/02/2023	
JC00092613	COFFEE MACHINE				22/02/2023	22/02/2024	22/02/2023	
JC00092614	COFFEE GRINDER				22/02/2023	22/02/2024	22/02/2023	
JC00092615	RCD POWERBOARD				22/02/2023	22/02/2024	22/02/2023	
JC00092616	RCD POWERBOARD				22/02/2023	22/02/2024	22/02/2023	
JC00092617	EXTN LEAD				22/02/2023	22/02/2024	22/02/2023	
JC00092618	EXTN LEAD				22/02/2023	22/02/2024	22/02/2023	
JC00092619	COFFEE MACHINE				22/02/2023	22/02/2024	22/02/2023	
JC00092620	COFFEE MACHINE				22/02/2023	22/02/2024	22/02/2023	
JC00092621	COFFEE GRINDER				22/02/2023	22/02/2024	22/02/2023	
JC00092622	EXTN LEAD				22/02/2023	22/02/2024	22/02/2023	
JC00092623	EXTN LEAD				22/02/2023	22/02/2024	22/02/2023	
JC00092624	COFFEE MACHINE				22/02/2023	22/02/2024	22/02/2023	
JC00092625	COFFEE MACHINE				22/02/2023	22/02/2024	22/02/2023	
JC00092626	RCD POWERBOARD				22/02/2023	22/02/2024	22/02/2023	
JC00092627	COFFEE GRINDER				22/02/2023	22/02/2024	22/02/2023	
JC00092628	COFFEE MACHINE				22/02/2023	22/02/2024	22/02/2023	
JC00092629	EXTN LEAD				22/02/2023	22/02/2024	22/02/2023	
JC00092630	HEAT SEALER				22/02/2023	22/02/2024	22/02/2023	
JC00092631	COFFEE GRINDER				22/02/2023	22/02/2024	22/02/2023	
JC00092632	COFFEE GRINDER				22/02/2023	22/02/2024	22/02/2023	
JC00092633	SONOS SPEAKER				22/02/2023	22/02/2024	22/02/2023	
JC00092634	COFFEE MACHINE				22/02/2023	22/02/2024	22/02/2023	
JC00092635	COFFEE MACHINE				22/02/2023	22/02/2024	22/02/2023	
JC00092636	EXTN LEAD				22/02/2023	22/02/2024	22/02/2023	



Asset ID	Description	Make	Model	Serial No	Last Test	Next Test	Last Visual	Next Visual
JC00092637	MILK FRIDGE				22/02/2023	22/02/2024	22/02/2023	
JC00092638	MILK FRIDGE				22/02/2023	22/02/2024	22/02/2023	
JC00092639	MILK FRIDGE				22/02/2023	22/02/2024	22/02/2023	
JC00092640	MILK FRIDGE				22/02/2023	22/02/2024	22/02/2023	
JC00092641	MILK FRIDGE				22/02/2023	22/02/2024	22/02/2023	
JC00092642	EXTN LEAD				22/02/2023	22/02/2024	22/02/2023	
JC00092643	EXTN LEAD				22/02/2023	22/02/2024	22/02/2023	
JC00092644	EXTN LEAD				22/02/2023	22/02/2024	22/02/2023	
JC00092645	COFFEE MACHINE				22/02/2023	22/02/2024	22/02/2023	
JC00092646	COFFEE MACHINE				22/02/2023	22/02/2024	22/02/2023	
JC00092647	COFFEE GRINDER				22/02/2023	22/02/2024	22/02/2023	
JC00092648	RCD POWERBOARD				22/02/2023	22/02/2024	22/02/2023	
JC00092649	EXTN LEAD				22/02/2023	22/02/2024	22/02/2023	
JC00092650	EXTN LEAD				22/02/2023	22/02/2024	22/02/2023	
JC00092651	EXTN LEAD				22/02/2023	22/02/2024	22/02/2023	
JC00092652	EXTN LEAD				22/02/2023	22/02/2024	22/02/2023	
JC00092653	EXTN LEAD				22/02/2023	22/02/2024	22/02/2023	
JC00092654	GRINDER				22/02/2023	22/02/2024	22/02/2023	
JC00092655	RCD POWERBOARD				22/02/2023	22/02/2024	22/02/2023	
JC00092656	RCD POWERBOARD				22/02/2023	22/02/2024	22/02/2023	
JC00092657	EXTN LEAD				22/02/2023	22/02/2024	22/02/2023	
JC00092658	RCD POWERBOARD	ARLEC 30MA			22/02/2023		22/02/2023	22/02/2024
JC00092659	RCD POWERBOARD	HPM 30MA			22/02/2023		22/02/2023	22/02/2024
JC00092660	EXTN LEAD				22/02/2023	22/02/2024	22/02/2023	
JC00092661	EXTN LEAD				22/02/2023	22/02/2024	22/02/2023	
JC00092662	EXTN LEAD				22/02/2023	22/02/2024	22/02/2023	
JC00092663	EXTN LEAD				22/02/2023	22/02/2024	22/02/2023	
JC00092664	RCD POWERBOARD				22/02/2023	22/02/2024	22/02/2023	
JC00092665	EXTN LEAD				22/02/2023	22/02/2024	22/02/2023	
JC00092666	EXTN LEAD				22/02/2023	22/02/2024	22/02/2023	
JC00092667	POWERBOARD				22/02/2023	22/02/2024	22/02/2023	
JC00092668	POWERBOARD				22/02/2023	22/02/2024	22/02/2023	
JC00092669	EXTN LEAD				22/02/2023	22/02/2024	22/02/2023	
JC00092670	EXTN LEAD				22/02/2023	22/02/2024	22/02/2023	
JC00092671	EXTN LEAD				22/02/2023	22/02/2024	22/02/2023	
JC00092672	EXTN LEAD	20AMP			22/02/2023	22/02/2024	22/02/2023	
JC00092673	EXTN LEAD				22/02/2023	22/02/2024	22/02/2023	
JC00092674	EXTN LEAD				22/02/2023	22/02/2024	22/02/2023	
JC00092675	EXTN LEAD				22/02/2023	22/02/2024	22/02/2023	
JC00092676	COFFEE GRINDER				22/02/2023	22/02/2024	22/02/2023	
JC00092677	PUMP				22/02/2023	22/02/2024	22/02/2023	
JC00092678	PUMP				22/02/2023	22/02/2024	22/02/2023	
JC00092679	COFFEE MACHINE				22/02/2023	22/02/2024	22/02/2023	
JC00092680	COFFEE GRINDER				22/02/2023	22/02/2024	22/02/2023	



Asset ID	Description	Make	Model	Serial No	Last Test	Next Test	Last Visual	Next Visual
JC00092681	EXTN LEAD				22/02/2023	22/02/2024	22/02/2023	
JC00092682	EXTN LEAD				22/02/2023	22/02/2024	22/02/2023	
JC00092683	COFFEE MACHINE				22/02/2023	22/02/2024	22/02/2023	
JC00092684	RCD POWERBOARD				22/02/2023	22/02/2024	22/02/2023	
JC00092685	RCD POWERBOARD				22/02/2023	22/02/2024	22/02/2023	
JC00092686	POWERBOARD				22/02/2023	22/02/2024	22/02/2023	
JC00092687	POWERBOARD				22/02/2023	22/02/2024	22/02/2023	
JC00092688	FRIDGE				22/02/2023	22/02/2024	22/02/2023	
JC00092689	3PH LEAD				22/02/2023	22/02/2024	22/02/2023	
JC00092690	3PH LEAD TO SINGLE PH				22/02/2023	22/02/2024	22/02/2023	
JC00092691	3PH LEAD TO SINGLE PH				22/02/2023	22/02/2024	22/02/2023	
JC00092692	FRIDGE				22/02/2023	22/02/2024	22/02/2023	
JC00092693	FRIDGE				22/02/2023	22/02/2024	22/02/2023	

Total Assets: 99

Detailed Latest Test Results

COFFEE ON CUE
19 Hall St
YARRAVILLE 3013



Client: COFFEE ON CUE

Site: COFFEE ON CUE

Location: 22_02_23				
Asset ID: JC00092595	Description: COFFEE MCHINE	User: M.SNELL	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	22/02/2023			Pass
Flexible cord	22/02/2023			Pass
Cover / Guards	22/02/2023			Pass
Earth Continuity	22/02/2023	0.19	ohm	Pass
Insulation Voltage	22/02/2023	500	V	Information
Insulation	22/02/2023	> 19.99	MOhm	Pass
				Overall: Pass

Asset ID: JC00092596	Description: COFFEE MACHINE8	User: M.SNELL	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	22/02/2023			Pass
Flexible cord	22/02/2023			Pass
Cover / Guards	22/02/2023			Pass
Earth Continuity	22/02/2023	0.16	ohm	Pass
Insulation Voltage	22/02/2023	500	V	Information
Insulation	22/02/2023	> 19.99	MOhm	Pass
				Overall: Pass

Asset ID: JC00092597	Description: EXTN LEAD	User: M.SNELL	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	22/02/2023			Pass
Flexible cord	22/02/2023			Pass
Cover / Guards	22/02/2023			Pass
IEC Lead Continuity	22/02/2023	0.39	ohm	Pass
Insulation Voltage	22/02/2023	500	V	Information
Insulation	22/02/2023	> 19.99	MOhm	Pass
IEC Lead Polarity	22/02/2023			Pass
				Overall: Pass

Asset ID: JC00092598	Description: RCD POWERBOARD	User: M.SNELL	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	22/02/2023			Pass
Flexible cord	22/02/2023			Pass
Cover / Guards	22/02/2023			Pass
RCD Trip Time Current (Portable)	22/02/2023	30	mA	Information
RCD Trip Time Angle (Portable)	22/02/2023	0	degrees	Information
				Overall: Pass



RCD Trip Time (Portable)	22/02/2023	28	ms	Pass
RCD Trip Time Current (Portable)	22/02/2023	30	mA	Information
RCD Trip Time Angle (Portable)	22/02/2023	180	degrees	Information
RCD Trip Time (Portable)	22/02/2023	18	ms	Pass
IEC Lead Continuity	22/02/2023	0.2	ohm	Pass
IEC Lead Continuity	22/02/2023	0.19	ohm	Pass
IEC Lead Continuity	22/02/2023	0.2	ohm	Pass
IEC Lead Continuity	22/02/2023	0.18	ohm	Pass
Insulation Voltage	22/02/2023	500	V	Information
Insulation	22/02/2023	> 19.99	MOhm	Pass
IEC Lead Polarity	22/02/2023			Pass
IEC Lead Polarity	22/02/2023			Pass
Live Voltage	22/02/2023	243.5	V	Information
Load Current	22/02/2023	0.074	A	Information
PE Conductor Current	22/02/2023	0.03	mA	Pass
				Overall: Pass

Asset ID: JC00092599	Description: EXTN LEAD	User: M.SNELL	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	22/02/2023			Pass
Flexible cord	22/02/2023			Pass
Cover / Guards	22/02/2023			Pass
IEC Lead Continuity	22/02/2023	0.16	ohm	Pass
Insulation Voltage	22/02/2023	500	V	Information
Insulation	22/02/2023	> 19.99	MOhm	Pass
IEC Lead Polarity	22/02/2023			Pass
				Overall: Pass

Asset ID: JC00092600	Description: EXTN LEAD	User: M.SNELL	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	22/02/2023			Pass
Flexible cord	22/02/2023			Pass
Cover / Guards	22/02/2023			Pass
IEC Lead Continuity	22/02/2023	0.69	ohm	Pass
Insulation Voltage	22/02/2023	500	V	Information
Insulation	22/02/2023	> 19.99	MOhm	Pass
IEC Lead Polarity	22/02/2023			Pass
				Overall: Pass

Asset ID: JC00092601	Description: COFFEE MACHINE	User: M.SNELL	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	22/02/2023			Pass
				Overall: Pass



Flexible cord	22/02/2023			Pass
Cover / Guards	22/02/2023			Pass
Earth Continuity	22/02/2023	0.12	ohm	Pass
Insulation Voltage	22/02/2023	500	V	Information
Insulation	22/02/2023	> 19.99	MOhm	Pass
Overall: Pass				

Asset ID: JC00092602	Description: COFFEE MACHINE	User: M.SNELL	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	22/02/2023			Pass
Flexible cord	22/02/2023			Pass
Cover / Guards	22/02/2023			Pass
Earth Continuity	22/02/2023	0.11	ohm	Pass
Insulation Voltage	22/02/2023	500	V	Information
Insulation	22/02/2023	> 19.99	MOhm	Pass
Overall: Pass				

Asset ID: JC00092603	Description: COFFEE GRINDER	User: M.SNELL	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	22/02/2023			Pass
Flexible cord	22/02/2023			Pass
Cover / Guards	22/02/2023			Pass
Earth Continuity	22/02/2023	0.21	ohm	Pass
Insulation Voltage	22/02/2023	500	V	Information
Insulation	22/02/2023	> 19.99	MOhm	Pass
Overall: Pass				

Asset ID: JC00092604	Description: COFFEE MACHINE	User: M.SNELL	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	22/02/2023			Pass
Flexible cord	22/02/2023			Pass
Cover / Guards	22/02/2023			Pass
Earth Continuity	22/02/2023	0.15	ohm	Pass
Insulation Voltage	22/02/2023	500	V	Information
Insulation	22/02/2023	> 19.99	MOhm	Pass
Overall: Pass				

Asset ID: JC00092605	Description: COFFEE MACHINE	User: M.SNELL	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	22/02/2023			Pass
Flexible cord	22/02/2023			Pass
Cover / Guards	22/02/2023			Pass
Overall: Pass				



Earth Continuity	22/02/2023	0.14	ohm	Pass
Insulation Voltage	22/02/2023	500	V	Information
Insulation	22/02/2023	> 19.99	MOhm	Pass
Overall: Pass				

Asset ID: JC00092606	Description: COFFEE GRINDER	User: M.SNELL	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	22/02/2023			Pass
Flexible cord	22/02/2023			Pass
Cover / Guards	22/02/2023			Pass
Earth Continuity	22/02/2023	0.15	ohm	Pass
Insulation Voltage	22/02/2023	500	V	Information
Insulation	22/02/2023	> 19.99	MOhm	Pass
Overall: Pass				

Asset ID: JC00092607	Description: EXTN LEAD	User: M.SNELL	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	22/02/2023			Pass
Flexible cord	22/02/2023			Pass
Cover / Guards	22/02/2023			Pass
IEC Lead Continuity	22/02/2023	0.7	ohm	Pass
Insulation Voltage	22/02/2023	500	V	Information
Insulation	22/02/2023	> 19.99	MOhm	Pass
IEC Lead Polarity	22/02/2023			Pass
Overall: Pass				

Asset ID: JC00092608	Description: EXTN LEAD	User: M.SNELL	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	22/02/2023			Pass
Flexible cord	22/02/2023			Pass
Cover / Guards	22/02/2023			Pass
IEC Lead Continuity	22/02/2023	0.7	ohm	Pass
Insulation Voltage	22/02/2023	500	V	Information
Insulation	22/02/2023	> 19.99	MOhm	Pass
IEC Lead Polarity	22/02/2023			Pass
Overall: Pass				

Asset ID: JC00092609	Description: RCD POWERBOARD	User: M.SNELL	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	22/02/2023			Pass
Flexible cord	22/02/2023			Pass
Cover / Guards	22/02/2023			Pass
Overall: Pass				



RCD Trip Time Current (Portable)	22/02/2023	30	mA	Information
RCD Trip Time Angle (Portable)	22/02/2023	0	degrees	Information
RCD Trip Time (Portable)	22/02/2023	19	ms	Pass
RCD Trip Time Current (Portable)	22/02/2023	30	mA	Information
RCD Trip Time Angle (Portable)	22/02/2023	180	degrees	Information
RCD Trip Time (Portable)	22/02/2023	28	ms	Pass
IEC Lead Continuity	22/02/2023	0.14	ohm	Pass
IEC Lead Continuity	22/02/2023	0.15	ohm	Pass
IEC Lead Continuity	22/02/2023	0.14	ohm	Pass
IEC Lead Continuity	22/02/2023	0.15	ohm	Pass
Insulation Voltage	22/02/2023	500	V	Information
Insulation	22/02/2023	> 19.99	MOhm	Pass
IEC Lead Polarity	22/02/2023			Pass
IEC Lead Polarity	22/02/2023			Pass
Live Voltage	22/02/2023	248.1	V	Information
Load Current	22/02/2023	0.068	A	Information
PE Conductor Current	22/02/2023	0.03	mA	Pass

Overall: Pass

Asset ID: JC00092610	Description: EXTN LEAD	User: M.SNELL	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	22/02/2023			Pass
Flexible cord	22/02/2023			Pass
Cover / Guards	22/02/2023			Pass
IEC Lead Continuity	22/02/2023	0.66	ohm	Pass
Insulation Voltage	22/02/2023	500	V	Information
Insulation	22/02/2023	> 19.99	MOhm	Pass
IEC Lead Polarity	22/02/2023			Pass

Overall: Pass

Asset ID: JC00092611	Description: EXTN LEAD	User: M.SNELL	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	22/02/2023			Pass
Flexible cord	22/02/2023			Pass
Cover / Guards	22/02/2023			Pass
IEC Lead Continuity	22/02/2023	0.66	ohm	Pass
Insulation Voltage	22/02/2023	500	V	Information
Insulation	22/02/2023	> 19.99	MOhm	Pass
IEC Lead Polarity	22/02/2023			Pass

Overall: Pass

Asset ID: JC00092612	Description: COFFEE MACHINE	User: M.SNELL	Test Instrument: Seaward PrimeTest Elite 23F-0519	
----------------------	-----------------------------	---------------	---	--



Test Type	Date	Result	Unit	Status
Plugs	22/02/2023			Pass
Flexible cord	22/02/2023			Pass
Cover / Guards	22/02/2023			Pass
Earth Continuity	22/02/2023	0.2	ohm	Pass
Insulation Voltage	22/02/2023	500	V	Information
Insulation	22/02/2023	> 19.99	MOhm	Pass
Overall: Pass				

Asset ID: JC00092613	Description: COFFEE MACHINE	User: M.SNELL	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	22/02/2023			Pass
Flexible cord	22/02/2023			Pass
Cover / Guards	22/02/2023			Pass
Earth Continuity	22/02/2023	0.19	ohm	Pass
Insulation Voltage	22/02/2023	500	V	Information
Insulation	22/02/2023	> 19.99	MOhm	Pass
Overall: Pass				

Asset ID: JC00092614	Description: COFFEE GRINDER	User: M.SNELL	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	22/02/2023			Pass
Flexible cord	22/02/2023			Pass
Cover / Guards	22/02/2023			Pass
Earth Continuity	22/02/2023	0.2	ohm	Pass
Insulation Voltage	22/02/2023	500	V	Information
Insulation	22/02/2023	> 19.99	MOhm	Pass
Overall: Pass				

Asset ID: JC00092615	Description: RCD POWERBOARD	User: M.SNELL	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	22/02/2023			Pass
Flexible cord	22/02/2023			Pass
Cover / Guards	22/02/2023			Pass
RCD Trip Time Current (Portable)	22/02/2023	30	mA	Information
RCD Trip Time Angle (Portable)	22/02/2023	0	degrees	Information
RCD Trip Time (Portable)	22/02/2023	43	ms	Pass
RCD Trip Time Current (Portable)	22/02/2023	30	mA	Information
RCD Trip Time Angle (Portable)	22/02/2023	180	degrees	Information
RCD Trip Time (Portable)	22/02/2023	33	ms	Pass
Overall: Pass				



IEC Lead Continuity	22/02/2023	0.16	ohm	Pass
IEC Lead Continuity	22/02/2023	0.16	ohm	Pass
IEC Lead Continuity	22/02/2023	0.14	ohm	Pass
IEC Lead Continuity	22/02/2023	0.14	ohm	Pass
Insulation Voltage	22/02/2023	500	V	Information
Insulation	22/02/2023	> 19.99	MOhm	Pass
IEC Lead Polarity	22/02/2023			Pass
IEC Lead Polarity	22/02/2023			Pass
Live Voltage	22/02/2023	253.1	V	Information
Load Current	22/02/2023	0.066	A	Information
PE Conductor Current	22/02/2023	0.03	mA	Pass
Overall: Pass				

Asset ID: JC00092616	Description: RCD POWERBOARD	User: M.SNELL	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	22/02/2023			Pass
Flexible cord	22/02/2023			Pass
Cover / Guards	22/02/2023			Pass
RCD Trip Time Current (Portable)	22/02/2023	30	mA	Information
RCD Trip Time Angle (Portable)	22/02/2023	0	degrees	Information
RCD Trip Time (Portable)	22/02/2023	28	ms	Pass
RCD Trip Time Current (Portable)	22/02/2023	30	mA	Information
RCD Trip Time Angle (Portable)	22/02/2023	180	degrees	Information
RCD Trip Time (Portable)	22/02/2023	18	ms	Pass
IEC Lead Continuity	22/02/2023	0.19	ohm	Pass
IEC Lead Continuity	22/02/2023	0.18	ohm	Pass
IEC Lead Continuity	22/02/2023	0.18	ohm	Pass
IEC Lead Continuity	22/02/2023	0.18	ohm	Pass
Insulation Voltage	22/02/2023	500	V	Information
Insulation	22/02/2023	> 19.99	MOhm	Pass
IEC Lead Polarity	22/02/2023			Pass
IEC Lead Polarity	22/02/2023			Pass
Live Voltage	22/02/2023	249.7	V	Information
Load Current	22/02/2023	0.057	A	Information
PE Conductor Current	22/02/2023	0.03	mA	Pass
Overall: Pass				

Asset ID: JC00092617	Description: EXTN LEAD	User: M.SNELL	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	22/02/2023			Pass
Flexible cord	22/02/2023			Pass
Overall: Pass				



Cover / Guards	22/02/2023			Pass
IEC Lead Continuity	22/02/2023	0.42	ohm	Pass
Insulation Voltage	22/02/2023	500	V	Information
Insulation	22/02/2023	> 19.99	MOhm	Pass
IEC Lead Polarity	22/02/2023			Pass
				Overall: Pass

Asset ID: JC00092618	Description: EXTN LEAD	User: M.SNELL	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	22/02/2023			Pass
Flexible cord	22/02/2023			Pass
Cover / Guards	22/02/2023			Pass
IEC Lead Continuity	22/02/2023	0.41	ohm	Pass
Insulation Voltage	22/02/2023	500	V	Information
Insulation	22/02/2023	> 19.99	MOhm	Pass
IEC Lead Polarity	22/02/2023			Pass
				Overall: Pass

Asset ID: JC00092619	Description: COFFEE MACHINE	User: M.SNELL	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	22/02/2023			Pass
Flexible cord	22/02/2023			Pass
Cover / Guards	22/02/2023			Pass
Earth Continuity	22/02/2023	0.14	ohm	Pass
Insulation Voltage	22/02/2023	500	V	Information
Insulation	22/02/2023	> 19.99	MOhm	Pass
				Overall: Pass

Asset ID: JC00092620	Description: COFFEE MACHINE	User: M.SNELL	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	22/02/2023			Pass
Flexible cord	22/02/2023			Pass
Cover / Guards	22/02/2023			Pass
Earth Continuity	22/02/2023	0.14	ohm	Pass
Insulation Voltage	22/02/2023	500	V	Information
Insulation	22/02/2023	> 19.99	MOhm	Pass
				Overall: Pass

Asset ID: JC00092621	Description: COFFEE GRINDER	User: M.SNELL	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	22/02/2023			Pass
Flexible cord	22/02/2023			Pass
				Overall: Pass



Cover / Guards	22/02/2023			Pass
Earth Continuity	22/02/2023	0.14	ohm	Pass
Insulation Voltage	22/02/2023	500	V	Information
Insulation	22/02/2023	> 19.99	MOhm	Pass
Overall: Pass				

Asset ID: JC00092622	Description: EXTN LEAD	User: M.SNELL	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	22/02/2023			Pass
Flexible cord	22/02/2023			Pass
Cover / Guards	22/02/2023			Pass
IEC Lead Continuity	22/02/2023	0.53	ohm	Pass
Insulation Voltage	22/02/2023	500	V	Information
Insulation	22/02/2023	> 19.99	MOhm	Pass
IEC Lead Polarity	22/02/2023			Pass
Overall: Pass				

Asset ID: JC00092623	Description: EXTN LEAD	User: M.SNELL	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	22/02/2023			Pass
Flexible cord	22/02/2023			Pass
Cover / Guards	22/02/2023			Pass
IEC Lead Continuity	22/02/2023	0.52	ohm	Pass
Insulation Voltage	22/02/2023	500	V	Information
Insulation	22/02/2023	> 19.99	MOhm	Pass
IEC Lead Polarity	22/02/2023			Pass
Overall: Pass				

Asset ID: JC00092624	Description: COFFEE MACHINE	User: M.SNELL	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	22/02/2023			Pass
Flexible cord	22/02/2023			Pass
Cover / Guards	22/02/2023			Pass
Earth Continuity	22/02/2023	0.15	ohm	Pass
Insulation Voltage	22/02/2023	500	V	Information
Insulation	22/02/2023	> 19.99	MOhm	Pass
Live Voltage	22/02/2023	254.8	V	Information
Load Current	22/02/2023	0.022	A	Information
PE Conductor Current	22/02/2023	0.37	mA	Pass
Overall: Pass				

Asset ID: JC00092625	Description: COFFEE MACHINE	User: M.SNELL	Test Instrument: Seaward PrimeTest Elite 23F-0519	
----------------------	-----------------------------	---------------	---	--



Test Type	Date	Result	Unit	Status
Plugs	22/02/2023			Pass
Flexible cord	22/02/2023			Pass
Cover / Guards	22/02/2023			Pass
Earth Continuity	22/02/2023	0.16	ohm	Pass
Insulation Voltage	22/02/2023	500	V	Information
Insulation	22/02/2023	> 19.99	MOhm	Pass
				Overall: Pass

Test Type	Date	Result	Unit	Status
Plugs	22/02/2023			Pass
Flexible cord	22/02/2023			Pass
Cover / Guards	22/02/2023			Pass
RCD Trip Time Current (Portable)	22/02/2023	30	mA	Information
RCD Trip Time Angle (Portable)	22/02/2023	0	degrees	Information
RCD Trip Time (Portable)	22/02/2023	9	ms	Pass
RCD Trip Time Current (Portable)	22/02/2023	30	mA	Information
RCD Trip Time Angle (Portable)	22/02/2023	180	degrees	Information
RCD Trip Time (Portable)	22/02/2023	19	ms	Pass
IEC Lead Continuity	22/02/2023	0.17	ohm	Pass
IEC Lead Continuity	22/02/2023	0.17	ohm	Pass
IEC Lead Continuity	22/02/2023	0.17	ohm	Pass
IEC Lead Continuity	22/02/2023	0.17	ohm	Pass
Insulation Voltage	22/02/2023	500	V	Information
Insulation	22/02/2023	> 19.99	MOhm	Pass
IEC Lead Polarity	22/02/2023			Pass
IEC Lead Polarity	22/02/2023			Pass
Live Voltage	22/02/2023	249.7	V	Information
Load Current	22/02/2023	0.057	A	Information
PE Conductor Current	22/02/2023	0.03	mA	Pass
				Overall: Pass

Test Type	Date	Result	Unit	Status
Plugs	22/02/2023			Pass
Flexible cord	22/02/2023			Pass
Cover / Guards	22/02/2023			Pass
Earth Continuity	22/02/2023	0.15	ohm	Pass
Insulation Voltage	22/02/2023	500	V	Information
Insulation	22/02/2023	> 19.99	MOhm	Pass
				Overall: Pass



Asset ID: JC00092628	Description: COFFEE MACHINE	User: M.SNELL	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	22/02/2023			Pass
Flexible cord	22/02/2023			Pass
Cover / Guards	22/02/2023			Pass
Earth Continuity	22/02/2023	0.16	ohm	Pass
Insulation Resistance	22/02/2023	> 19.99	MOhm	Pass
				Overall: Pass

Asset ID: JC00092629	Description: EXTN LEAD	User: M.SNELL	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	22/02/2023			Pass
Flexible cord	22/02/2023			Pass
Cover / Guards	22/02/2023			Pass
IEC Lead Continuity	22/02/2023	0.12	ohm	Pass
Insulation Voltage	22/02/2023	500	V	Information
Insulation	22/02/2023	> 19.99	MOhm	Pass
IEC Lead Polarity	22/02/2023			Pass
				Overall: Pass

Asset ID: JC00092630	Description: HEAT SEALER	User: M.SNELL	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	22/02/2023			Pass
Flexible cord	22/02/2023			Pass
Cover / Guards	22/02/2023			Pass
Earth Continuity	22/02/2023	0.27	ohm	Pass
Insulation Voltage	22/02/2023	500	V	Information
Insulation	22/02/2023	> 19.99	MOhm	Pass
				Overall: Pass

Asset ID: JC00092631	Description: COFFEE GRINDER	User: M.SNELL	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	22/02/2023			Pass
Flexible cord	22/02/2023			Pass
Cover / Guards	22/02/2023			Pass
Earth Continuity	22/02/2023	0.23	ohm	Pass
Insulation Voltage	22/02/2023	500	V	Information
Insulation	22/02/2023	> 19.99	MOhm	Pass
				Overall: Pass

Asset ID: JC00092632	Description: COFFEE GRINDER	User: M.SNELL	Test Instrument: Seaward PrimeTest Elite 23F-0519	
----------------------	-----------------------------	---------------	---	--



Test Type	Date	Result	Unit	Status
Plugs	22/02/2023			Pass
Flexible cord	22/02/2023			Pass
Cover / Guards	22/02/2023			Pass
Earth Continuity	22/02/2023	0.3	ohm	Pass
Insulation Voltage	22/02/2023	500	V	Information
Insulation	22/02/2023	> 19.99	MOhm	Pass
Overall: Pass				

Test Type	Date	Result	Unit	Status
Asset ID: JC00092633 Description: SONOS SPEAKER User: M.SNELL Test Instrument: Seaward PrimeTest Elite 23F-0519				
Plugs	22/02/2023			Pass
Flexible cord	22/02/2023			Pass
Cover / Guards	22/02/2023			Pass
Insulation Voltage	22/02/2023	500	V	Information
Insulation	22/02/2023	> 19.99	MOhm	Pass
Overall: Pass				

Test Type	Date	Result	Unit	Status
Asset ID: JC00092634 Description: COFFEE MACHINE User: M.SNELL Test Instrument: Seaward PrimeTest Elite 23F-0519				
Plugs	22/02/2023			Pass
Flexible cord	22/02/2023			Pass
Cover / Guards	22/02/2023			Pass
Earth Continuity	22/02/2023	0.14	ohm	Pass
Insulation Voltage	22/02/2023	500	V	Information
Insulation	22/02/2023	> 19.99	MOhm	Pass
Overall: Pass				

Test Type	Date	Result	Unit	Status
Asset ID: JC00092635 Description: COFFEE MACHINE User: M.SNELL Test Instrument: Seaward PrimeTest Elite 23F-0519				
Plugs	22/02/2023			Pass
Flexible cord	22/02/2023			Pass
Cover / Guards	22/02/2023			Pass
Earth Continuity	22/02/2023	0.13	ohm	Pass
Insulation Voltage	22/02/2023	500	V	Information
Insulation	22/02/2023	> 19.99	MOhm	Pass
Overall: Pass				

Test Type	Date	Result	Unit	Status
Asset ID: JC00092636 Description: EXTN LEAD User: M.SNELL Test Instrument: Seaward PrimeTest Elite 23F-0519				
Plugs	22/02/2023			Pass
Flexible cord	22/02/2023			Pass
Overall: Pass				



Cover / Guards	22/02/2023			Pass
IEC Lead Continuity	22/02/2023	0.33	ohm	Pass
Insulation Voltage	22/02/2023	500	V	Information
Insulation	22/02/2023	> 19.99	MOhm	Pass
IEC Lead Polarity	22/02/2023			Pass
Overall: Pass				

Asset ID: JC00092637	Description: MILK FRIDGE	User: M.SNELL	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	22/02/2023			Pass
Flexible cord	22/02/2023			Pass
Cover / Guards	22/02/2023			Pass
Earth Continuity	22/02/2023	0.45	ohm	Pass
Insulation Voltage	22/02/2023	500	V	Information
Insulation	22/02/2023	> 19.99	MOhm	Pass
Overall: Pass				

Asset ID: JC00092638	Description: MILK FRIDGE	User: M.SNELL	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	22/02/2023			Pass
Flexible cord	22/02/2023			Pass
Cover / Guards	22/02/2023			Pass
Earth Continuity	22/02/2023	0.53	ohm	Pass
Insulation Voltage	22/02/2023	500	V	Information
Insulation	22/02/2023	> 19.99	MOhm	Pass
Overall: Pass				

Asset ID: JC00092639	Description: MILK FRIDGE	User: M.SNELL	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	22/02/2023			Pass
Flexible cord	22/02/2023			Pass
Cover / Guards	22/02/2023			Pass
Earth Continuity	22/02/2023	0.42	ohm	Pass
Insulation Voltage	22/02/2023	500	V	Information
Insulation	22/02/2023	> 19.99	MOhm	Pass
Overall: Pass				

Asset ID: JC00092640	Description: MILK FRIDGE	User: M.SNELL	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	22/02/2023			Pass
Flexible cord	22/02/2023			Pass
Cover / Guards	22/02/2023			Pass
Overall: Pass				



Earth Continuity	22/02/2023	0.41	ohm	Pass
Insulation Voltage	22/02/2023	500	V	Information
Insulation	22/02/2023	> 19.99	MOhm	Pass
Overall: Pass				

Asset ID: JC00092641	Description: MILK FRIDGE	User: M.SNELL	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	22/02/2023			Pass
Flexible cord	22/02/2023			Pass
Cover / Guards	22/02/2023			Pass
Earth Continuity	22/02/2023	0.43	ohm	Pass
Insulation Voltage	22/02/2023	500	V	Information
Insulation	22/02/2023	> 19.99	MOhm	Pass
Overall: Pass				

Asset ID: JC00092642	Description: EXTN LEAD	User: M.SNELL	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	22/02/2023			Pass
Flexible cord	22/02/2023			Pass
Cover / Guards	22/02/2023			Pass
IEC Lead Continuity	22/02/2023	0.24	ohm	Pass
Insulation Voltage	22/02/2023	500	V	Information
Insulation	22/02/2023	> 19.99	MOhm	Pass
IEC Lead Polarity	22/02/2023			Pass
Overall: Pass				

Asset ID: JC00092643	Description: EXTN LEAD	User: M.SNELL	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	22/02/2023			Pass
Flexible cord	22/02/2023			Pass
Cover / Guards	22/02/2023			Pass
IEC Lead Continuity	22/02/2023	0.14	ohm	Pass
Insulation Voltage	22/02/2023	500	V	Information
Insulation	22/02/2023	> 19.99	MOhm	Pass
IEC Lead Polarity	22/02/2023			Pass
Overall: Pass				

Asset ID: JC00092644	Description: EXTN LEAD	User: M.SNELL	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	22/02/2023			Pass
Flexible cord	22/02/2023			Pass
Cover / Guards	22/02/2023			Pass
Overall: Pass				



IEC Lead Continuity	22/02/2023	0.52	ohm	Pass
Insulation Voltage	22/02/2023	500	V	Information
Insulation	22/02/2023	> 19.99	MOhm	Pass
IEC Lead Polarity	22/02/2023			Pass
Overall: Pass				

Asset ID: JC00092645	Description: COFFEE MACHINE	User: M.SNELL	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	22/02/2023			Pass
Flexible cord	22/02/2023			Pass
Cover / Guards	22/02/2023			Pass
Earth Continuity	22/02/2023	0.44	ohm	Pass
Insulation Voltage	22/02/2023	500	V	Information
Insulation	22/02/2023	> 19.99	MOhm	Pass
Overall: Pass				

Asset ID: JC00092646	Description: COFFEE MACHINE	User: M.SNELL	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	22/02/2023			Pass
Flexible cord	22/02/2023			Pass
Cover / Guards	22/02/2023			Pass
Earth Continuity	22/02/2023	0.2	ohm	Pass
Insulation Voltage	22/02/2023	500	V	Information
Insulation	22/02/2023	> 19.99	MOhm	Pass
Overall: Pass				

Asset ID: JC00092647	Description: COFFEE GRINDER	User: M.SNELL	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	22/02/2023			Pass
Flexible cord	22/02/2023			Pass
Cover / Guards	22/02/2023			Pass
Earth Continuity	22/02/2023	0.17	ohm	Pass
Insulation Voltage	22/02/2023	500	V	Information
Insulation	22/02/2023	> 19.99	MOhm	Pass
Overall: Pass				

Asset ID: JC00092648	Description: RCD POWERBOARD	User: M.SNELL	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	22/02/2023			Pass
Flexible cord	22/02/2023			Pass
Cover / Guards	22/02/2023			Pass
Overall: Pass				



RCD Trip Time Current (Portable)	22/02/2023	30	mA	Information
RCD Trip Time Angle (Portable)	22/02/2023	0	degrees	Information
RCD Trip Time (Portable)	22/02/2023	43	ms	Pass
RCD Trip Time Current (Portable)	22/02/2023	30	mA	Information
RCD Trip Time Angle (Portable)	22/02/2023	180	degrees	Information
RCD Trip Time (Portable)	22/02/2023	33	ms	Pass
IEC Lead Continuity	22/02/2023	0.19	ohm	Pass
IEC Lead Continuity	22/02/2023	0.18	ohm	Pass
IEC Lead Continuity	22/02/2023	0.18	ohm	Pass
IEC Lead Continuity	22/02/2023	0.18	ohm	Pass
Insulation Voltage	22/02/2023	500	V	Information
Insulation	22/02/2023	> 19.99	MOhm	Pass
IEC Lead Polarity	22/02/2023			Pass
IEC Lead Polarity	22/02/2023			Pass
Live Voltage	22/02/2023	257.4	V	Information
Load Current	22/02/2023	0.049	A	Information
PE Conductor Current	22/02/2023	0.03	mA	Pass

Overall: Pass

Asset ID: JC00092649	Description: EXTN LEAD	User: M.SNELL	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	22/02/2023			Pass
Flexible cord	22/02/2023			Pass
Cover / Guards	22/02/2023			Pass
IEC Lead Continuity	22/02/2023	0.22	ohm	Pass
Insulation Voltage	22/02/2023	500	V	Information
Insulation	22/02/2023	> 19.99	MOhm	Pass
IEC Lead Polarity	22/02/2023			Pass

Overall: Pass

Asset ID: JC00092650	Description: EXTN LEAD	User: M.SNELL	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	22/02/2023			Pass
Flexible cord	22/02/2023			Pass
Cover / Guards	22/02/2023			Pass
IEC Lead Continuity	22/02/2023	0.43	ohm	Pass
Insulation Voltage	22/02/2023	500	V	Information
Insulation	22/02/2023	> 19.99	MOhm	Pass
IEC Lead Polarity	22/02/2023			Pass

Overall: Pass

Asset ID: JC00092651	Description: EXTN LEAD	User: M.SNELL	Test Instrument: Seaward PrimeTest Elite 23F-0519	
----------------------	------------------------	---------------	---	--



Test Type	Date	Result	Unit	Status
Plugs	22/02/2023			Pass
Flexible cord	22/02/2023			Pass
Cover / Guards	22/02/2023			Pass
IEC Lead Continuity	22/02/2023	0.46	ohm	Pass
Insulation Voltage	22/02/2023	500	V	Information
Insulation	22/02/2023	> 19.99	MOhm	Pass
IEC Lead Polarity	22/02/2023			Pass
				Overall: Pass

Test Type	Date	Result	Unit	Status	
Asset ID: JC00092652		Description: EXTN LEAD		User: M.SNELL	Test Instrument: Seaward PrimeTest Elite 23F-0519
Plugs	22/02/2023			Pass	
Flexible cord	22/02/2023			Pass	
Cover / Guards	22/02/2023			Pass	
IEC Lead Continuity	22/02/2023	0.44	ohm	Pass	
Insulation Voltage	22/02/2023	500	V	Information	
Insulation	22/02/2023	> 19.99	MOhm	Pass	
IEC Lead Polarity	22/02/2023			Pass	
				Overall: Pass	

Test Type	Date	Result	Unit	Status	
Asset ID: JC00092653		Description: EXTN LEAD		User: M.SNELL	Test Instrument: Seaward PrimeTest Elite 23F-0519
Plugs	22/02/2023			Pass	
Flexible cord	22/02/2023			Pass	
Cover / Guards	22/02/2023			Pass	
IEC Lead Continuity	22/02/2023	0.57	ohm	Pass	
Insulation Voltage	22/02/2023	500	V	Information	
Insulation	22/02/2023	> 19.99	MOhm	Pass	
IEC Lead Polarity	22/02/2023			Pass	
				Overall: Pass	

Test Type	Date	Result	Unit	Status	
Asset ID: JC00092654		Description: GRINDER		User: M.SNELL	Test Instrument: Seaward PrimeTest Elite 23F-0519
Plugs	22/02/2023			Pass	
Flexible cord	22/02/2023			Pass	
Cover / Guards	22/02/2023			Pass	
Earth Continuity	22/02/2023	0.13	ohm	Pass	
Insulation Voltage	22/02/2023	500	V	Information	
Insulation	22/02/2023	> 19.99	MOhm	Pass	
Live Voltage	22/02/2023	252.9	V	Information	
Load Current	22/02/2023	0.016	A	Information	
PE Conductor Current	22/02/2023	0.37	mA	Pass	
				Overall: Pass	



Asset ID: JC00092655		Description: RCD POWERBOARD		User: M.SNELL		Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status			
Plugs	22/02/2023			Pass			
Flexible cord	22/02/2023			Pass			
Cover / Guards	22/02/2023			Pass			
RCD Trip Time Current (Portable)	22/02/2023	30	mA	Information			
RCD Trip Time Angle (Portable)	22/02/2023	0	degrees	Information			
RCD Trip Time (Portable)	22/02/2023	9	ms	Pass			
RCD Trip Time Current (Portable)	22/02/2023	30	mA	Information			
RCD Trip Time Angle (Portable)	22/02/2023	180	degrees	Information			
RCD Trip Time (Portable)	22/02/2023	19	ms	Pass			
IEC Lead Continuity	22/02/2023	0.22	ohm	Pass			
IEC Lead Continuity	22/02/2023	0.22	ohm	Pass			
IEC Lead Continuity	22/02/2023	0.21	ohm	Pass			
IEC Lead Continuity	22/02/2023	0.21	ohm	Pass			
Insulation Voltage	22/02/2023	500	V	Information			
Insulation	22/02/2023	> 19.99	MOhm	Pass			
IEC Lead Polarity	22/02/2023			Pass			
IEC Lead Polarity	22/02/2023			Pass			
Live Voltage	22/02/2023	254.6	V	Information			
Load Current	22/02/2023	0.052	A	Information			
PE Conductor Current	22/02/2023	0.03	mA	Pass			
Overall: Pass							

Asset ID: JC00092656		Description: RCD POWERBOARD		User: M.SNELL		Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status			
Plugs	22/02/2023			Pass			
Flexible cord	22/02/2023			Pass			
Cover / Guards	22/02/2023			Pass			
RCD Trip Time Current (Portable)	22/02/2023	30	mA	Information			
RCD Trip Time Angle (Portable)	22/02/2023	0	degrees	Information			
RCD Trip Time (Portable)	22/02/2023	19	ms	Pass			
RCD Trip Time Current (Portable)	22/02/2023	30	mA	Information			
RCD Trip Time Angle (Portable)	22/02/2023	180	degrees	Information			
RCD Trip Time (Portable)	22/02/2023	28	ms	Pass			
IEC Lead Continuity	22/02/2023	0.2	ohm	Pass			
IEC Lead Continuity	22/02/2023	0.2	ohm	Pass			
IEC Lead Continuity	22/02/2023	0.19	ohm	Pass			
Overall: Pass							



IEC Lead Continuity	22/02/2023	0.2	ohm	Pass
Insulation Voltage	22/02/2023	500	V	Information
Insulation	22/02/2023	> 19.99	MOhm	Pass
IEC Lead Polarity	22/02/2023			Pass
IEC Lead Polarity	22/02/2023			Pass
Live Voltage	22/02/2023	254.3	V	Information
Load Current	22/02/2023	0.025	A	Information
PE Conductor Current	22/02/2023	0.03	mA	Pass
Overall: Pass				

Asset ID: JC00092657	Description: EXTN LEAD	User: M.SNELL	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	22/02/2023			Pass
Flexible cord	22/02/2023			Pass
Cover / Guards	22/02/2023			Pass
IEC Lead Continuity	22/02/2023	0.17	ohm	Pass
Insulation Voltage	22/02/2023	500	V	Information
Insulation	22/02/2023	> 19.99	MOhm	Pass
IEC Lead Polarity	22/02/2023			Pass
Overall: Pass				

Asset ID: JC00092658	Description: RCD POWERBOARD	User: M.SNELL	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Comments: FAIL - DAMAGED CORD				
Test Type	Date	Result	Unit	Status
Flexible cord	22/02/2023			Fail
Overall: Fail				

Asset ID: JC00092659	Description: RCD POWERBOARD	User: M.SNELL	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Comments: FAIL - RCD WONT TRIP				
Test Type	Date	Result	Unit	Status
Safety Devices	22/02/2023			Fail
Overall: Fail				

Asset ID: JC00092660	Description: EXTN LEAD	User: M.SNELL	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	22/02/2023			Pass
Flexible cord	22/02/2023			Pass
Cover / Guards	22/02/2023			Pass
IEC Lead Continuity	22/02/2023	0.17	ohm	Pass
Insulation Voltage	22/02/2023	500	V	Information
Insulation	22/02/2023	> 19.99	MOhm	Pass
IEC Lead Polarity	22/02/2023			Pass
Overall: Pass				



Asset ID: JC00092661		Description: EXTN LEAD		User: M.SNELL		Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status			
Plugs	22/02/2023			Pass			
Flexible cord	22/02/2023			Pass			
Cover / Guards	22/02/2023			Pass			
IEC Lead Continuity	22/02/2023	0.59	ohm	Pass			
Insulation Voltage	22/02/2023	500	V	Information			
Insulation	22/02/2023	> 19.99	MOhm	Pass			
IEC Lead Polarity	22/02/2023			Pass			
Overall: Pass							

Asset ID: JC00092662		Description: EXTN LEAD		User: M.SNELL		Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status			
Plugs	22/02/2023			Pass			
Flexible cord	22/02/2023			Pass			
Cover / Guards	22/02/2023			Pass			
IEC Lead Continuity	22/02/2023	0.42	ohm	Pass			
Insulation Voltage	22/02/2023	500	V	Information			
Insulation	22/02/2023	> 19.99	MOhm	Pass			
IEC Lead Polarity	22/02/2023			Pass			
Overall: Pass							

Asset ID: JC00092663		Description: EXTN LEAD		User: M.SNELL		Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status			
Plugs	22/02/2023			Pass			
Flexible cord	22/02/2023			Pass			
Cover / Guards	22/02/2023			Pass			
IEC Lead Continuity	22/02/2023	0.4	ohm	Pass			
Insulation Voltage	22/02/2023	500	V	Information			
Insulation	22/02/2023	> 19.99	MOhm	Pass			
IEC Lead Polarity	22/02/2023			Pass			
Overall: Pass							

Asset ID: JC00092664		Description: RCD POWERBOARD		User: M.SNELL		Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status			
Plugs	22/02/2023			Pass			
Flexible cord	22/02/2023			Pass			
Cover / Guards	22/02/2023			Pass			
RCD Trip Time Current (Portable)	22/02/2023	30	mA	Information			
RCD Trip Time Angle (Portable)	22/02/2023	0	degrees	Information			
RCD Trip Time (Portable)	22/02/2023	18	ms	Pass			
Overall: Pass							



RCD Trip Time Current (Portable)	22/02/2023	30	mA	Information
RCD Trip Time Angle (Portable)	22/02/2023	180	degrees	Information
RCD Trip Time (Portable)	22/02/2023	28	ms	Pass
IEC Lead Continuity	22/02/2023	0.19	ohm	Pass
IEC Lead Continuity	22/02/2023	0.18	ohm	Pass
IEC Lead Continuity	22/02/2023	0.18	ohm	Pass
IEC Lead Continuity	22/02/2023	0.18	ohm	Pass
IEC Lead Continuity	22/02/2023	0.17	ohm	Pass
Insulation Voltage	22/02/2023	500	V	Information
Insulation	22/02/2023	> 19.99	MOhm	Pass
IEC Lead Polarity	22/02/2023			Pass
IEC Lead Polarity	22/02/2023			Pass
Live Voltage	22/02/2023	251.8	V	Information
Load Current	22/02/2023	0.052	A	Information
PE Conductor Current	22/02/2023	0.03	mA	Pass
				Overall: Pass

Asset ID: JC00092665	Description: EXTN LEAD	User: M.SNELL	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	22/02/2023			Pass
Flexible cord	22/02/2023			Pass
Cover / Guards	22/02/2023			Pass
IEC Lead Continuity	22/02/2023	0.53	ohm	Pass
Insulation Voltage	22/02/2023	500	V	Information
Insulation	22/02/2023	> 19.99	MOhm	Pass
IEC Lead Polarity	22/02/2023			Pass
				Overall: Pass

Asset ID: JC00092666	Description: EXTN LEAD	User: M.SNELL	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	22/02/2023			Pass
Flexible cord	22/02/2023			Pass
Cover / Guards	22/02/2023			Pass
IEC Lead Continuity	22/02/2023	0.26	ohm	Pass
Insulation Voltage	22/02/2023	500	V	Information
Insulation	22/02/2023	> 19.99	MOhm	Pass
IEC Lead Polarity	22/02/2023			Pass
				Overall: Pass

Asset ID: JC00092667	Description: POWERBOARD	User: M.SNELL	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	22/02/2023			Pass
				Overall: Pass



Flexible cord	22/02/2023			Pass
Cover / Guards	22/02/2023			Pass
IEC Lead Continuity	22/02/2023	0.22	ohm	Pass
Insulation Voltage	22/02/2023	500	V	Information
Insulation	22/02/2023	> 19.99	MOhm	Pass
IEC Lead Polarity	22/02/2023			Pass
				Overall: Pass

Asset ID: JC00092668	Description: POWERBOARD	User: M.SNELL	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	22/02/2023			Pass
Flexible cord	22/02/2023			Pass
Cover / Guards	22/02/2023			Pass
IEC Lead Continuity	22/02/2023	0.22	ohm	Pass
Insulation Voltage	22/02/2023	500	V	Information
Insulation	22/02/2023	> 19.99	MOhm	Pass
IEC Lead Polarity	22/02/2023			Pass
				Overall: Pass

Asset ID: JC00092669	Description: EXTN LEAD	User: M.SNELL	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	22/02/2023			Pass
Flexible cord	22/02/2023			Pass
Cover / Guards	22/02/2023			Pass
IEC Lead Continuity	22/02/2023	0.22	ohm	Pass
Insulation Voltage	22/02/2023	500	V	Information
Insulation	22/02/2023	> 19.99	MOhm	Pass
IEC Lead Polarity	22/02/2023			Pass
				Overall: Pass

Asset ID: JC00092670	Description: EXTN LEAD	User: M.SNELL	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	22/02/2023			Pass
Flexible cord	22/02/2023			Pass
Cover / Guards	22/02/2023			Pass
IEC Lead Continuity	22/02/2023	0.22	ohm	Pass
Insulation Voltage	22/02/2023	500	V	Information
Insulation	22/02/2023	> 19.99	MOhm	Pass
IEC Lead Polarity	22/02/2023			Pass
				Overall: Pass

Asset ID: JC00092671	Description: EXTN LEAD	User: M.SNELL	Test Instrument: Seaward PrimeTest Elite 23F-0519	
----------------------	------------------------	---------------	---	--



Test Type	Date	Result	Unit	Status
Plugs	22/02/2023			Pass
Flexible cord	22/02/2023			Pass
Cover / Guards	22/02/2023			Pass
IEC Lead Continuity	22/02/2023	0.5	ohm	Pass
Insulation Voltage	22/02/2023	500	V	Information
Insulation	22/02/2023	> 19.99	MOhm	Pass
IEC Lead Polarity	22/02/2023			Pass
Overall: Pass				

Asset ID: JC00092672	Description: EXTN LEAD	User: M.SNELL	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	22/02/2023			Pass
Flexible cord	22/02/2023			Pass
Cover / Guards	22/02/2023			Pass
IEC Lead Continuity	22/02/2023	0.65	ohm	Pass
Insulation Voltage	22/02/2023	500	V	Information
Insulation	22/02/2023	> 19.99	MOhm	Pass
IEC Lead Polarity	22/02/2023			Pass
Overall: Pass				

Asset ID: JC00092673	Description: EXTN LEAD	User: M.SNELL	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	22/02/2023			Pass
Flexible cord	22/02/2023			Pass
Cover / Guards	22/02/2023			Pass
IEC Lead Continuity	22/02/2023	0.45	ohm	Pass
Insulation Voltage	22/02/2023	500	V	Information
Insulation	22/02/2023	> 19.99	MOhm	Pass
IEC Lead Polarity	22/02/2023			Pass
Overall: Pass				

Asset ID: JC00092674	Description: EXTN LEAD	User: M.SNELL	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	22/02/2023			Pass
Flexible cord	22/02/2023			Pass
Cover / Guards	22/02/2023			Pass
IEC Lead Continuity	22/02/2023	0.32	ohm	Pass
Insulation Voltage	22/02/2023	500	V	Information
Insulation	22/02/2023	> 19.99	MOhm	Pass
IEC Lead Polarity	22/02/2023			Pass
Overall: Pass				

Asset ID: JC00092675	Description: EXTN LEAD	User: M.SNELL	Test Instrument: Seaward PrimeTest Elite 23F-0519	
----------------------	------------------------	---------------	---	--



Test Type	Date	Result	Unit	Status
Plugs	22/02/2023			Pass
Flexible cord	22/02/2023			Pass
Cover / Guards	22/02/2023			Pass
IEC Lead Continuity	22/02/2023	0.33	ohm	Pass
Insulation Voltage	22/02/2023	500	V	Information
Insulation	22/02/2023	> 19.99	MOhm	Pass
IEC Lead Polarity	22/02/2023			Pass
Overall: Pass				

Asset ID: JC00092676	Description: COFFEE GRINDER	User: M.SNELL	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	22/02/2023			Pass
Flexible cord	22/02/2023			Pass
Cover / Guards	22/02/2023			Pass
Earth Continuity	22/02/2023	0.15	ohm	Pass
Insulation Voltage	22/02/2023	500	V	Information
Insulation	22/02/2023	> 19.99	MOhm	Pass
Overall: Pass				

Asset ID: JC00092677	Description: PUMP	User: M.SNELL	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	22/02/2023			Pass
Flexible cord	22/02/2023			Pass
Cover / Guards	22/02/2023			Pass
Earth Continuity	22/02/2023	0.13	ohm	Pass
Insulation Voltage	22/02/2023	500	V	Information
Insulation	22/02/2023	> 19.99	MOhm	Pass
Overall: Pass				

Asset ID: JC00092678	Description: PUMP	User: M.SNELL	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	22/02/2023			Pass
Flexible cord	22/02/2023			Pass
Cover / Guards	22/02/2023			Pass
Earth Continuity	22/02/2023	0.14	ohm	Pass
Insulation Voltage	22/02/2023	500	V	Information
Insulation	22/02/2023	> 19.99	MOhm	Pass
Overall: Pass				

Asset ID: JC00092679	Description: COFFEE MACHINE	User: M.SNELL	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Overall: Pass				



Test Type	Date	Result	Unit	Status
Plugs	22/02/2023			Pass
Flexible cord	22/02/2023			Pass
Cover / Guards	22/02/2023			Pass
Earth Continuity	22/02/2023	0.14	ohm	Pass
Insulation Voltage	22/02/2023	500	V	Information
Insulation	22/02/2023	> 19.99	MOhm	Pass
Overall: Pass				

Asset ID: JC00092680	Description: COFFEE GRINDER	User: M.SNELL	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	22/02/2023			Pass
Flexible cord	22/02/2023			Pass
Cover / Guards	22/02/2023			Pass
Earth Continuity	22/02/2023	0.15	ohm	Pass
Insulation Voltage	22/02/2023	500	V	Information
Insulation	22/02/2023	> 19.99	MOhm	Pass
Overall: Pass				

Asset ID: JC00092681	Description: EXTN LEAD	User: M.SNELL	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	22/02/2023			Pass
Flexible cord	22/02/2023			Pass
Cover / Guards	22/02/2023			Pass
IEC Lead Continuity	22/02/2023	0.59	ohm	Pass
Insulation Voltage	22/02/2023	500	V	Information
Insulation	22/02/2023	> 19.99	MOhm	Pass
IEC Lead Polarity	22/02/2023			Pass
Overall: Pass				

Asset ID: JC00092682	Description: EXTN LEAD	User: M.SNELL	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	22/02/2023			Pass
Flexible cord	22/02/2023			Pass
Cover / Guards	22/02/2023			Pass
IEC Lead Continuity	22/02/2023	0.57	ohm	Pass
Insulation Voltage	22/02/2023	500	V	Information
Insulation	22/02/2023	> 19.99	MOhm	Pass
IEC Lead Polarity	22/02/2023			Pass
Overall: Pass				

Asset ID: JC00092683	Description: COFFEE MACHINE	User: M.SNELL	Test Instrument: Seaward PrimeTest Elite 23F-0519	
----------------------	-----------------------------	---------------	---	--



Test Type	Date	Result	Unit	Status
Plugs	22/02/2023			Pass
Flexible cord	22/02/2023			Pass
Cover / Guards	22/02/2023			Pass
Earth Continuity	22/02/2023	0.19	ohm	Pass
Insulation Voltage	22/02/2023	500	V	Information
Insulation	22/02/2023	> 19.99	MOhm	Pass
				Overall: Pass

Test Type	Date	Result	Unit	Status
Plugs	22/02/2023			Pass
Flexible cord	22/02/2023			Pass
Cover / Guards	22/02/2023			Pass
RCD Trip Time Current (Portable)	22/02/2023	30	mA	Information
RCD Trip Time Angle (Portable)	22/02/2023	0	degrees	Information
RCD Trip Time (Portable)	22/02/2023	28	ms	Pass
RCD Trip Time Current (Portable)	22/02/2023	30	mA	Information
RCD Trip Time Angle (Portable)	22/02/2023	180	degrees	Information
RCD Trip Time (Portable)	22/02/2023	17	ms	Pass
IEC Lead Continuity	22/02/2023	0.18	ohm	Pass
IEC Lead Continuity	22/02/2023	0.17	ohm	Pass
IEC Lead Continuity	22/02/2023	0.17	ohm	Pass
IEC Lead Continuity	22/02/2023	0.17	ohm	Pass
Insulation Voltage	22/02/2023	500	V	Information
Insulation	22/02/2023	> 19.99	MOhm	Pass
IEC Lead Polarity	22/02/2023			Pass
IEC Lead Polarity	22/02/2023			Pass
Live Voltage	22/02/2023	249.5	V	Information
Load Current	22/02/2023	0.057	A	Information
PE Conductor Current	22/02/2023	0.03	mA	Pass
				Overall: Pass

Test Type	Date	Result	Unit	Status
Plugs	22/02/2023			Pass
Flexible cord	22/02/2023			Pass
Cover / Guards	22/02/2023			Pass
RCD Trip Time Current (Portable)	22/02/2023	30	mA	Information
				Overall: Pass



RCD Trip Time Angle (Portable)	22/02/2023	0	degrees	Information
RCD Trip Time (Portable)	22/02/2023	28	ms	Pass
RCD Trip Time Current (Portable)	22/02/2023	30	mA	Information
RCD Trip Time Angle (Portable)	22/02/2023	180	degrees	Information
RCD Trip Time (Portable)	22/02/2023	18	ms	Pass
IEC Lead Continuity	22/02/2023	0.16	ohm	Pass
IEC Lead Continuity	22/02/2023	0.15	ohm	Pass
IEC Lead Continuity	22/02/2023	0.15	ohm	Pass
IEC Lead Continuity	22/02/2023	0.15	ohm	Pass
Insulation Voltage	22/02/2023	500	V	Information
Insulation	22/02/2023	> 19.99	MOhm	Pass
IEC Lead Polarity	22/02/2023			Pass
IEC Lead Polarity	22/02/2023			Pass
Live Voltage	22/02/2023	242.6	V	Information
Load Current	22/02/2023	0.036	A	Information
PE Conductor Current	22/02/2023	0.03	mA	Pass
Overall: Pass				

Asset ID: JC00092686	Description: POWERBOARD	User: M.SNELL	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Comments: EARH BOND ONLY				
Test Type	Date	Result	Unit	Status
Plugs	22/02/2023			Pass
Flexible cord	22/02/2023			Pass
Cover / Guards	22/02/2023			Pass
Earth Bond 200mA Pt-Pt	22/02/2023	0.05	ohm	Pass
Overall: Pass				

Asset ID: JC00092687	Description: POWERBOARD	User: M.SNELL	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Comments: EARH BOND ONLY				
Test Type	Date	Result	Unit	Status
Plugs	22/02/2023			Pass
Flexible cord	22/02/2023			Pass
Cover / Guards	22/02/2023			Pass
Earth Bond 200mA Pt-Pt	22/02/2023	0.05	ohm	Pass
Overall: Pass				

Asset ID: JC00092688	Description: FRIDGE	User: M.SNELL	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	22/02/2023			Pass
Flexible cord	22/02/2023			Pass
Cover / Guards	22/02/2023			Pass
Overall: Pass				



Earth Continuity	22/02/2023	0.2	ohm	Pass
Insulation Voltage	22/02/2023	500	V	Information
Insulation	22/02/2023	> 19.99	MOhm	Pass
Overall: Pass				

Asset ID: JC00092689	Description: 3PH LEAD	User: M.SNELL	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	22/02/2023			Pass
Flexible cord	22/02/2023			Pass
Cover / Guards	22/02/2023			Pass
Earth Bond 200mA Pt-Pt	22/02/2023	0.04	ohm	Pass
Earth Bond 200mA Pt-Pt	22/02/2023	0.04	ohm	Pass
Earth Bond 200mA Pt-Pt	22/02/2023	0.06	ohm	Pass
Earth Bond 200mA Pt-Pt	22/02/2023	0.04	ohm	Pass
Earth Bond 200mA Pt-Pt	22/02/2023	0.04	ohm	Pass
Overall: Pass				

Asset ID: JC00092690	Description: 3PH LEAD TO SINGLE PH	User: M.SNELL	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Comments: EARH BOND ONLY				
Test Type	Date	Result	Unit	Status
Plugs	22/02/2023			Pass
Flexible cord	22/02/2023			Pass
Cover / Guards	22/02/2023			Pass
Earth Bond 200mA Pt-Pt	22/02/2023	0.05	ohm	Pass
Overall: Pass				

Asset ID: JC00092691	Description: 3PH LEAD TO SINGLE PH	User: M.SNELL	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Comments: EARH BOND ONLY				
Test Type	Date	Result	Unit	Status
Plugs	22/02/2023			Pass
Flexible cord	22/02/2023			Pass
Cover / Guards	22/02/2023			Pass
Earth Bond 200mA Pt-Pt	22/02/2023	0.03	ohm	Pass
Overall: Pass				

Asset ID: JC00092692	Description: FRIDGE	User: M.SNELL	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	22/02/2023			Pass
Flexible cord	22/02/2023			Pass
Cover / Guards	22/02/2023			Pass
Earth Continuity	22/02/2023	0.11	ohm	Pass
Insulation Voltage	22/02/2023	500	V	Information
Overall: Pass				



Insulation	22/02/2023	> 19.99	MOhm	Pass
Overall: Pass				

Asset ID: JC00092693	Description: FRIDGE	User: M.SNELL	Test Instrument: Seaward PrimeTest Elite 23F-0519	
Test Type	Date	Result	Unit	Status
Plugs	22/02/2023			Pass
Flexible cord	22/02/2023			Pass
Cover / Guards	22/02/2023			Pass
Earth Continuity	22/02/2023	0.21	ohm	Pass
Insulation Voltage	22/02/2023	500	V	Information
Insulation	22/02/2023	> 19.99	MOhm	Pass
Overall: Pass				

Total Tests: 99