

Retrofitting Membrane Filtration Ultrafiltration System



CASE STUDY

Location: Stevenson, Alabama
Owner: Dekalb-Jackson Water Supply Dist.
Engineer: Greenhill Engineering Consult.
Contractor: Lambert, Inc.

Production Problem

The Dekalb-Jackson Water Treatment Plant opened in 2007. Previously the counties of Jackson and Dekalb provided water to residents by purchasing it from neighboring water districts. With increasing populations in Jackson and Dekalb counties it was necessary to construct a facility to produce their own water supply by drawing from the Tennessee River. Raw water has organics, which affect taste and odor, and turbidity spikes up to 30 NTU.

Membrane technology was originally selected because it provides a physical barrier against contaminants. However, the current membrane system did not meet expectations. Since start-up, operators faced problems with excessive fiber breaks and meeting production demands.

In addition to excessive fiber breaks the membrane system experienced frequent fouling, despite pretreatment. To reduce fouling, frequent chemical cleans were necessary. These cleans consumed time and made it difficult

to meet system demands. After years of altering operational and cleaning procedures in unsuccessful attempts to achieve production goals, Dekalb-Jackson Water Supply District was in need of a permanent solution.

Selecting a Solution

To remedy the situation, Dekalb-Jackson worked with Greenhill Engineering and WesTech to determine the best approach to replace the existing membrane system. As part of the evaluation, WesTech performed an eight (8) month long pilot study with a membrane filtration system incorporating Toray membranes.

The pilot study demonstrated consistent production of high quality filtrate under a variety of operating conditions with regular chemical cleans limited to once every 30 days. There were no fiber breaks

for the duration of the pilot, nor problems with fouling, regardless of flux rate. After successfully completing the pilot study WesTech was able to accurately design an ultrafiltration system to retrofit the existing membrane system.

At the Dekalb-Jackson Water Treatment Plant water is drawn from the river and pumped to one of two package treatment plants, previously provided by WesTech. Treated water from the package plants is then pumped to the membrane systems, and from the clearwell is sent to distribution.

WesTech's Ultrafiltration Membrane System, featuring Toray membrane modules, has a nominal pore size of 0.01 μm , providing exceptional removal of pathogen and particulate matter, achieving greater than 4.0 log removal of *Cryptosporidium* and *Giardia*, and greater than 1.5 removal of viruses.

Installation

WesTech worked closely with the plant, engineer, and contractor making detailed plans to minimize time the plant was offline during retrofit installation. With careful design and planning, WesTech was able to remove the old system and install the new system in a way that allowed the plant to be offline for less than a day.

Pilot Study

Flow	Range: 20.5-53.8 gpm Avg: 27.4 gpm
TMP	Range: 6.1-28 psi Avg: 12.5 psi
Normalized Flux	Range: 45-90 gfd Avg: 60 gfd
Outlet Turbidity	Avg: 0.012 NTU
Recovery	Range: 97.7%-98.7% Avg: 98.1%

WesTech®

 SWIRE WATER

Performance

The new membrane system performs substantially better than the previous system. The new WesTech ultrafiltration system has improved recovery from 91.7% to 96.9%, increased flux by 54%, and has reduced system energy consumption through a 60% decrease in average TMP. Chemical cleaning frequency has decreased from once every 15 days to once every 30 or more days, further reducing operating cost and allowing the plant more production time.

Ultrafiltration System	
Quantity	96 Modules
Material	PVDF
Membrane Area per Module	775 ft ²
Flux @ design temp	47.02 gfd
Design temp	8 °C
N. Flux at Design Temp(20°C)	65.32 gfd
Design Flow	3.0 MGD
Estimated Water Recovery	95.9%

DeKalb-Jackson Ultrafiltration System		
	Previous System	Retrofit System
System	4 Trains 16 modules per Train	3 Trains 32 modules per Train
Footprint	15' 10 5/8" x 4' 1 1/8"	17'11" x 6'4"
Membrane Surface Area	1227.1 ft ² per module	775 ft ² per module
Average System Flow	1.663 MGD	2.255 MGD
Average flux rate	23.62 gfd	36.35 gfd
Average TMP	13.50 psi	5.39 psi
Filtrate Turbidity	Avg: 0.026 NTU <0.1 NTU 99.4% <1.4NTU 100%	Avg: 0.0091 NTU <0.1 ntu 99.95% <0.238 ntu 100%
Recovery	Avg: 91.7%	Avg: 96.9%

Customer Satisfaction

Plant managers and operators are pleased with WesTech's superior service and quick work in retrofitting the plant. Tommy Bryant, Manager at the DeKalb-Jackson Water Treatment Plant stated:

"We feel fortunate, given the events that have transpired at our facility, to have chosen a company with the integrity that WesTech has shown, to be partnered with."

Thanks to WesTech's superior service, residents of DeKalb and Jackson counties have clean, high quality water from reliable equipment.

